

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106
1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400

TEST REPORT

Client : Paxwood Pty Ltd T/A Clever Choice Design Floors
Unit 1
164 Adderlely Street
West Auburn NSW 2144

Test Number : 20-003084
Issue Date : 3/07/2020
Print Date : 6/07/2020

Sample Description Clients Ref : "Clever Oak 14mm"
Engineered timber flooring
End Use : Flooring
Nominal Composition : Solid Oak veneer with multi layer ply core
Nominal Mass per Unit Area/Density : 750kg/m3
Nominal Thickness : 14mm

AS 4586-2013 Appendix A

Slip Resistance Classification of new Pedestrian Surface Materials Wet Pendulum Test Method

Date of Testing 02/07/2020
Test Temperature (20±5degC) 22 °C
Sample Preparation Washed with pH neutral detergent and dried
Test Direction Length
Fixed/Unfixed Unfixed
Slider No 96 Batch No 87
Length 1 2 3 4 5 SRV
British Pendulum 36 36 37 36 36 36
Number
Classification P3

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 08/11/2019
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

207919

44908

Page 1 of 1

© Australian Wool Testing Authority Ltd
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

- Chemical Testing : Accreditation No. 983
- Mechanical Testing : Accreditation No. 985
- Performance & Approvals Testing : Accreditation No. 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

APPROVED SIGNATORY



MICHAEL A. JACKSON B.Sc. (Hons)
MANAGING DIRECTOR